



- NOTES:
- FLOOR OF BOX TO BE TROWELED SMOOTH.
 - IF THE TOE OF SLOPE IS ALLOWED WITHIN THE R/W, INLET TYPE I BEGINS AT THE TOE RATHER THAN THE R/W LINE.
 - FOR OPEN DITCH APPROACH (TYPE II) THE 2' EXTENSION BEYOND R/W LINE IS NOT REQUIRED WHEN THE BACK OF WALK IS 2' OR MORE FROM THE R/W LINE, HOWEVER, CURB DRAIN SHALL EXTEND TO R/W LINE IN ALL CASES.
 - TOP OF INLET STRUCTURE (TYPE I & II) TO BE FLUSH WITH ADJACENT SURFACE WHERE PRACTICABLE.
 - A HEADED STEEL STUD 5/8" X 6 3/8" WITH HEAD D=1" ATTACHED BY A FULL PENETRATION BUTT WELD MAY BE USED AS AN ALTERNATE ANCHOR.
 - NORMAL CURB FACE AT POINT M AND Q, B+5" AT POINT N AND P.
 - THE 3" LEG OF THE INTERIOR ANCHORS SHALL BE PARALLEL TO THE TOP OF SIDEWALK.
 - ALL WORK SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE LATEST ADOPTED STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.

STEEL LIST

S	B	GALVANIZED STEEL ANGLE	ANCHOR	J BAR		
				SIZE	SPACING	LENGTH
1'-0"	3"	2 1/2" X 2" X 3/8"	2	#3	7"	1'-9"
1'-6"	"	"	"	"	"	2'-3"
2'-0"	"	"	"	"	"	2'-9"
2'-6"	"	"	"	"	"	3'-3"
3'-0"	"	"	3	"	"	3'-9"
3'-6"	"	"	"	"	6"	4'-3"
4'-0"	"	"	"	"	5"	4'-9"
4'-6"	4"	3 1/2" X 3" X 1/2"	"	"	6 1/2"	5'-3"
5'-0"	"	"	"	"	5"	5'-9"
5'-6"	"	"	"	"	4"	6'-3"
6'-0"	"	"	"	"	3 1/2"	6'-9"

CITY OF BURBANK - PUBLIC WORKS DEPARTMENT

REV	BY	DATE

CURB DRAIN NO. 2

APPROVED BY: *[Signature]* 6-1-92
Public Works Director Date

STANDARD PLAN
BS-108
SHEET 1 OF 1